



中国国家强制性产品认证证书



SITIAs
Worldwide Access

证书编号: 2020322304003035

认证委托人名称: ifm electronic gmbh
认证委托人地址: Friedrichstr. 1, Essen, Germany
生产者名称: ifm efector gmbh
生产者地址: ifm-Strasse 1, 88069, Tettnang, Germany
生产企业名称: ifm efector gmbh
企业地址: ifm-Strasse 1, 88069, Tettnang, Germany

产品名称: 转速开关
系列、规格、型号: DI103A, DI520A, DI521A, DI522A, DI523A, DI524A
标 准: GB/T 3836.1-2021、GB/T 3836.31-2021

认证模式: 型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求, 特发此证。
产品相关信息详见附件。

发证日期: 2023 年 04 月 29 日

有效期至: 2025 年 10 月 27 日

首次发证日期: 2020 年 10 月 28 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批 准:



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322304003035

APPLICANT: ifm electronic gmbh
ADDRESS: Friedrichstr. 1, Essen, Germany
MANUFACTURER: ifm efector gmbh
ADDRESS: ifm-Strasse 1, 88069, Tettnang, Germany
FACTORY: ifm efector gmbh
ADDRESS: ifm-Strasse 1, 88069, Tettnang, Germany
PRODUCT: Speed Switch
SERIES,SPECIFICATION,MODEL: DI103A, DI520A, DI521A, DI522A, DI523A, DI524A
STANDARDS: GB/T 3836.1-2021、GB/T 3836.31-2021

Type of Certification: Type test + Initial inspection + Surveillance inspection

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).
Refer to the attachment for detailed information.

Valid from: April 29, 2023

Valid until: October 27, 2025

Date of original certification: October 28, 2020

The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiias.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0008631



中国国家强制性产品认证证书



证书编号: 2020322304003035

附 件

产品名称: 转速开关

型号规格: DI103A, DI520A, DI521A, DI522A, DI523A, DI524A

防爆标志: Ex tc IIIC T80°C Dc

电气参数: DI103A: 额定电压 20~250V AC/DC, 额定电流 200mA AC/100mA DC;
DI520A, DI521A, DI522A, DI523A, DI524A: 额定电压 10~36V DC 额定电流 250mA DC。

相关报告编号: 2023S17402-011246

使用条件:

1. 特殊(限制)使用条件:
 - 1) 产品使用环境温度为-20°C~+60°C
 - 2) 产品外壳采用 4J 低能量进行冲击试验, 使用时须避免危险能量的冲击。
 - 3) 产品安装时应有防光(如日光和灯光)照措施。
2. 其他相关信息: 外壳防护等级为 IP65/IP67。

批 准:



上海仪器仪表自控系统检验测试所有限公司